



AVERAGE ANNUAL HEAT PUMP HSPF

YEAR	AVERAGE HSPF	YEAR	AVERAGE HSPF
1973	5.66	1990	6.98
1974	5.66	1991	7.08
1975	5.66	1992	7.19
1976	5.66	1993	7.30
1977	5.74	1994	7.38
1978	5.83	1995	7.39
1979	5.91	1996	7.40
1980	6.00	1997	7.39
1981	6.09	1998	7.29
1982	6.18	1999	7.47
1983	6.28	2000	7.46
1984	6.37	2001	7.49
1985	6.47	2002	7.49
1986	6.56	2003	7.53
1987	6.66	2004	7.56
1988	6.81	2005	7.58

AVERAGE ANNUAL SHIPPED SPACE-COOLING EFFICIENCY

YEAR	CENTRAL A/C SEER	HEAT PUMP SEER
1976	7.15	6.87
1977	7.18	6.89
1978	7.41	7.24
1979	7.45	7.34
1980	7.51	7.51
1981	7.73	7.70
1982	8.30	7.79
1983	8.44	8.23
1984	8.70	8.45
1985	8.84	8.56
1986	8.87	8.70
1987	8.95	8.93
1988	9.11	9.13
1989	9.23	9.26
1990	9.25	9.41
1991	9.44	9.73
1992	10.43	10.56
1993	10.52	10.82
1994	10.58	10.89
1995	10.52	10.93
1996	10.64	10.95
1997	10.63	10.93
1998	10.62	10.52
1999	10.23	11.24
2000	10.86	11.23
2001	10.95	11.31
2002	11.07	11.32
2003	11.22	11.48
2004	11.32	11.58
2005	11.33	11.69