

**EXISTING HOMES SPECIFICATIONS MANUAL**

# **AIR SEALING MEASURE CHECKLIST**

All work shall meet Energy Trust of Oregon specifications. **This checklist serves as a reference guide only.** Please refer to the 2017 Specifications Manual for additional information and clarification. Refer to Appendix D for recommended air sealing target areas.

A Blower Door test shall be performed prior to work being installed and again after work is installed to be considered a complete measure. Technicians operating the Blower Door shall adhere to program-specified procedures for diagnostic testing.

Air sealing shall be performed in the following sequence to prioritize energy-savings opportunities:

<input type="checkbox"/> 1. Between the attic and the conditioned space
<input type="checkbox"/> 2. Walls between the garage and the house
<input type="checkbox"/> 3. Floor above a crawlspace, or exterior walls of a conditioned basement
<input type="checkbox"/> 4. Walls between the conditioned space and the unconditioned space
<input type="checkbox"/> 5. Other opportunities as identified by Blower Door testing

If the final CFM measurement is below the minimum ventilation level (MVL), mechanical ventilation shall be installed. Refer to the MV section of the manual for further information.

**A functioning UL-listed carbon monoxide alarm is required as part of air sealing whenever a combustion appliance is present in the home, an attached garage, or another attached space.**

Print Name:	Signature:	Date:
-------------	------------	-------