

**HOME RETROFIT SPECIFICATIONS MANUAL**

**GAS FIREPLACE COMPLETE MEASURE CHECKLIST**

All work must meet Energy Trust of Oregon specifications. **This checklist serves as a reference guide only.** Please refer to the current Specifications Manual for additional information and clarification. Specific reference sections are noted in italics.

<input type="checkbox"/> A functioning UL-listed carbon monoxide alarm is installed in the home on every floor with a bedroom and according to manufacturer’s specifications. <i>IN 1.2</i>
<input type="checkbox"/> Unit is installed in a non-hazardous location maintaining proper clearance and does not compromise the structural integrity of the building. <i>IN 1.14 and IN 1.15</i>
<input type="checkbox"/> Unit has a permanent label identifying make, model and serial number. <i>IN 1.14</i>
<input type="checkbox"/> Combustion air intake and exhaust venting are unobstructed. <i>FP 1.1 and FP 1.2</i>
<input type="checkbox"/> Entire gas line from meter to appliance is free of leaks. <i>IN 1.15</i>
<input type="checkbox"/> Unit is fully accessible for future servicing if necessary. <i>FP 1.3</i>
<input type="checkbox"/> Unit is installed in accordance with manufacturer’s specifications and jurisdictional codes. <i>IN 1.14</i>

Print Name:	Signature:	Date:
-------------	------------	-------